

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1446:0108 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: EVAX SYSTEMS20 McDermott Dr, Branford, CT 06405
Contact: Bill Witherspoon (203) 315-5116 Fax (203) 315-5118
Email: billw@pottersignal.com

DESIGN: Model EF-UDACT digital alarm communicator transmitter. Unit gives the fire control system the capability to operate in a remote or central station service. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC, 32 mA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and ETL label.

APPROVAL: Listed as digital alarm communicator transmitter for use with listee's separately listed compatible Model EF1 and EF2 fire alarm control units (CSFM Listing Nos. 7165-1446:106 and 7170-1446:107).

08-01-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division