

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-1446:0110

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: EVAX SYSTEMS20 McDermott Dr, Branford, CT 06405
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Model EF-TH Addressable Fixed Temperature Heat Detector. Detector is intended to be used with listee's Model EF1, EF2, EF3 and EF3V* fire alarm control panels. Refer to listee's data sheet for additional detailed product description and operational considerations

RATING: 17 - 28 vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, product designation, and ETL label.

APPROVAL: Listed as an addressable heat detector for use with *Models EF-B4 and EF-B6 bases and listee's Models EF1, EF2, EF3 and EF3V* fire alarm control units (CSFM Listing number 7165-1446:0106. Refer to manufacturer's Installation Manual for details.

06-19-12 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **September 12, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division